

# SUBMITTAL DRAWING MD 200R

# **ROUND MANUAL BALANCING DAMPERS**

## STANDARD CONSTRUCTION

#### **FRAME**

20 ga. (.91) galvanized steel. 7" long. (178)

#### **BLADES**

16 GA (0.062) galvanized steel

#### **FINISH**

Mill galvanized


#### **CONTROL SHAFT**

1/2"(0.5) square axle extending beyond frame c/w locking hand quadrant

#### **BEARINGS**

Stainless steel

Dimensions in brackets ( ) indicate millimeters.



Hand Quadrant Stand-Off bracket


#### **MAXIMUM TEMPERATURE**

250 deg. F (121 deg. C)

## **DAMPER SIZES**

4" Minimum 20" Maximum

Unit supplied approximately 1/8" (6) smaller than given duct diameter.



Project: Contractor: Location: Address:

Architect P.O. Number:

Engineer:

Date: